



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946

Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



OR NELAP 4072


INORGANIC COMPOUNDS (IOC) REPORT

Client Name: St. Peter Catholic School
84105 Highway 11
Milton-Freewater, OR 97862

Reference Number: 19-36124
Project: St. Peter Catholic School

Date Collected: 9/17/19 07:20
System ID Number:
Lab Number: 046-70064
Sample Location: Front Office Drinking Fountain Right
Sample Purpose: Investigative or Other
Sample Composition:

Approved by: hkl

Authorized by: 
Patrick Miller, MS
QA Officer

Field ID:
System Group Type:
System Name:
County:
Source Number:
Multiple Sources:
Date Received: 9/19/19
Report Date: 9/25/19
Sample Type:
Sampled By: Maribel Ramirez
Sampler Phone:

DOH#	ANALYTES	RESULTS	UNITS	SRL	Trigger	MCL	Analyst	METHOD	Lab	Analyzed	COMMENT
9	State Unregulated LEAD	ND	mg/L	0.001		0.015	bj	200.8	a	09/24/19	

NOTES:

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).
MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.
Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.
ND (Not Detected): indicates that the parameter was not detected above the Specified Reporting Limit (SRL).
An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.
If you have any questions concerning this report contact Patrick Miller, MS, QA Officer, at the toll-free phone number above.



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946

Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



OR NELAP 4072

INORGANIC COMPOUNDS (IOC) REPORT

Client Name: St. Peter Catholic School
84105 Highway 11
Milton-Freewater, OR 97862

Reference Number: 19-36124
Project: St. Peter Catholic School

Date Collected: 9/17/19 07:21
System ID Number:
Lab Number: 046-70065
Sample Location: Front Office Drinking Fountain Left
Sample Purpose: Investigative or Other
Sample Composition:

Approved by: hkl

Authorized by:

Patrick Miller, MS
QA Officer

Field ID:
System Group Type:
System Name:
County:
Source Number:
Multiple Sources:
Date Received: 9/19/19
Report Date: 9/25/19
Sample Type:
Sampled By: Maribel Ramirez
Sampler Phone:

DOH#	ANALYTES	RESULTS	UNITS	SRL	Trigger	MCL	Analyst	METHOD	Lab	Analyzed	COMMENT
9	State Unregulated LEAD	ND	mg/L	0.001		0.015	bj	200.8	a	09/24/19	

NOTES:

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).
MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.
Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.
ND (Not Detected): indicates that the parameter was not detected above the Specified Reporting Limit (SRL).
An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.
If you have any questions concerning this report contact Patrick Miller, MS, QA Officer, at the toll-free phone number above.



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946

Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



OR NELAP 4072

INORGANIC COMPOUNDS (IOC) REPORT

Client Name: St. Peter Catholic School
84105 Highway 11
Milton-Freewater, OR 97862

Reference Number: 19-36124
Project: St. Peter Catholic School

Date Collected: 9/17/19 07:26
System ID Number:
Lab Number: **046-70066**
Sample Location: K5 Classroom
Sample Purpose: Investigative or Other
Sample Composition:

Approved by: hkl

Authorized by:

Patrick Miller, MS
QA Officer

Field ID:
System Group Type:
System Name:
County:
Source Number:
Multiple Sources:
Date Received: 9/19/19
Report Date: 9/25/19
Sample Type:
Sampled By: Maribel Ramirez
Sampler Phone:

DOH#	ANALYTES	RESULTS	UNITS	SRL	Trigger	MCL	Analyst	METHOD	Lab	Analyzed	COMMENT
9	State Unregulated LEAD	0.005	mg/L	0.001		0.015	bj	200.8	a	09/24/19	

NOTES:

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).
MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.
Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.
ND (Not Detected): indicates that the parameter was not detected above the Specified Reporting Limit (SRL).
An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.
If you have any questions concerning this report contact Patrick Miller, MS, QA Officer, at the toll-free phone number above.



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946

Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



OR NELAP 4072

INORGANIC COMPOUNDS (IOC) REPORT

Client Name: St. Peter Catholic School
84105 Highway 11
Milton-Freewater, OR 97862

Reference Number: 19-36124
Project: St. Peter Catholic School

Date Collected: 9/17/19 07:27
System ID Number:
Lab Number: **046-70067**
Sample Location: K4 Classroom
Sample Purpose: Investigative or Other
Sample Composition:

Approved by: hkl

Authorized by:

Patrick Miller, MS
QA Officer

Field ID:
System Group Type:
System Name:
County:
Source Number:
Multiple Sources:
Date Received: 9/19/19
Report Date: 9/25/19
Sample Type:
Sampled By: Maribel Ramirez
Sampler Phone:

DOH#	ANALYTES	RESULTS	UNITS	SRL	Trigger	MCL	Analyst	METHOD	Lab	Analyzed	COMMENT
9	State Unregulated LEAD	0.006	mg/L	0.001		0.015	bj	200.8	a	09/24/19	

NOTES:

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).
MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.
Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.
ND (Not Detected): indicates that the parameter was not detected above the Specified Reporting Limit (SRL).
An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.
If you have any questions concerning this report contact Patrick Miller, MS, QA Officer, at the toll-free phone number above.



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946

Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



OR NELAP 4072

INORGANIC COMPOUNDS (IOC) REPORT

Client Name: St. Peter Catholic School
84105 Highway 11
Milton-Freewater, OR 97862

Reference Number: 19-36124
Project: St. Peter Catholic School

Date Collected: 9/17/19 07:30
System ID Number:
Lab Number: 046-70068
Sample Location: Kirkpatrick Center Drinking Fountain Right
Sample Purpose: Investigative or Other
Sample Composition:

Approved by: hkl

Authorized by:

Patrick Miller, MS
QA Officer

Field ID:
System Group Type:
System Name:
County:
Source Number:
Multiple Sources:
Date Received: 9/19/19
Report Date: 9/25/19
Sample Type:
Sampled By: Maribel Ramirez
Sampler Phone:

DOH#	ANALYTES	RESULTS	UNITS	SRL	Trigger	MCL	Analyst	METHOD	Lab	Analyzed	COMMENT
9	State Unregulated LEAD	0.001	mg/L	0.001		0.015	bj	200.8	a	09/24/19	

NOTES:

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).
MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.
Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.
ND (Not Detected): indicates that the parameter was not detected above the Specified Reporting Limit (SRL).
An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.
If you have any questions concerning this report contact Patrick Miller, MS, QA Officer, at the toll-free phone number above.



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946

Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



OR NELAP 4072

INORGANIC COMPOUNDS (IOC) REPORT

Client Name: St. Peter Catholic School
84105 Highway 11
Milton-Freewater, OR 97862

Reference Number: 19-36124
Project: St. Peter Catholic School

Date Collected: 9/17/19 07:31
System ID Number:
Lab Number: **046-70069**
Sample Location: Kirkpatrick Center Drinking Fountain Left
Sample Purpose: Investigative or Other
Sample Composition:

Approved by: hkl

Authorized by:

Patrick Miller, MS
QA Officer

Field ID:
System Group Type:
System Name:
County:
Source Number:
Multiple Sources:
Date Received: 9/19/19
Report Date: 9/25/19
Sample Type:
Sampled By: Maribel Ramirez
Sampler Phone:

DOH#	ANALYTES	RESULTS	UNITS	SRL	Trigger	MCL	Analyst	METHOD	Lab	Analyzed	COMMENT
9	State Unregulated LEAD	0.001	mg/L	0.001		0.015	bj	200.8	a	09/24/19	

NOTES:

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).
MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.
Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.
ND (Not Detected): indicates that the parameter was not detected above the Specified Reporting Limit (SRL).
An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.
If you have any questions concerning this report contact Patrick Miller, MS, QA Officer, at the toll-free phone number above.